

Table LBS2.1a: Existing sewer system summary - WWTP's and Pumps

Details of bulk discharge points and Wastewater Treatment Plants (WWTP's)		
Name	Capacity (kℓ/d)	IPDWF (ℓ/s)
Ashton WWTP	3 400	(No info)
Bonnievale WWTP	1 500	(No info)
McGregor WWTP	300	(No info)
Montagu WWTP	1 800	(No info)
Robertson WWTP	3 800	(No info)

Existing Pump Stations			
Town or Zone	Name	Capacity (ℓ/s)	Diameter of rising main (mm)
Ashton	Unipack PS	11*	150
	Zolani PS	5*	90*
	Ashton PS	45*	200
Bonnievale	Pump 1	12*	160
	Pump 2	18*	200
	Pump 3	44*	250
	Pump 4	29*	110**
	Pump 5	8*	110
	Pump 6	25*	110**
	Pump 7	24*	110
McGregor	(None)		
Montagu	Ashbury PS	8*	100
	Avalon Springs PS	8*	100
	Montagu PS M1	39**	200
	Montagu PS M2	20**	100**
Robertson	Nkqubela PS 1	6.5*	100**
	Nkqubela PS 2	8*	100**
	Nkqubela PS 3	6.5*	100**
	Robertson PS 1	12*	150**
	Silwerstrand PS ***	12*	150

* required minimum capacity - to be verified

** to be verified

*** private pump station