

Table LBS3.4: Present water demand summary

Scenario	Water use (kℓ/d)	NRW est. (kℓ/d)	AADD (kℓ/d)
Ashton sewerage system			
Actual	3 845	824	4 669
Theoretical, based on UWD's	3 963	748	4 710
Potential, assuming all stands occupied	5 534	1 062	6 596
Bonnievale sewerage system			
Actual	2 775	1 306	4 081
Theoretical, based on UWD's	2 884	721	3 605
Potential, assuming all stands occupied	3 848	962	4 810
McGregor sewerage system			
Actual	483	121	604
Theoretical, based on UWD's	485	86	570
Potential, assuming all stands occupied	891	157	1 048
Montagu sewerage system			
Actual	3 284	210	3 493
Theoretical, based on UWD's	3 347	372	3 719
Potential, assuming all stands occupied	5 171	575	5 746
Robertson sewerage system			
Actual	4 709	1 034	5 743
Theoretical, based on UWD's	4 781	844	5 625
Potential, assuming all stands occupied	7 015	1 238	8 252