

Table LBS6.2c: Land use and sewer flow composition - Existing McGregor System

McGregor Gravity

Gravity

McGregor WWTP

	UH1	UH2	UH3	UH4	UH5	UH6	UH7	UH8	UH9	UH10	UH11	UH12	UH13	UH14	UH15	Sewer	Water	PDDWF/
	LDRes	MDRes	HDRes	VHDRes	Other	Unknown	Bus/Comm	Cluster	Flats	None	Farm/AH	Educ	Gov/Inst	Ind	Large	PDDWF	AADD	AADD
Unit Erven (No. of)	24	20	43	167	0	0	4	1	5	0	0	0	0	0	18			
Domestic (kl/d)	14.00	7.70	14.80	48.30	0.00	0.00	2.70	0.60	2.80	0.00	0.00	0.00	0.00	0.00	5.30	96		
Base/Leakage (kl/d)	4.80	3.30	8.00	33.30	0.00	0.00	2.70	0.60	2.90	0.00	0.00	0.00	0.00	0.00	5.30	61		
Infiltration (kl/d)																20		
Outside Contr. (kl/d)																		
Total (kl/d)																177	261	68%
Unit Erven (No. of)	24	20	43	167	0	0	4	1	5	0	0	0	0	0	18			
Domestic (kl/d)	14.00	7.70	14.80	48.30	0.00	0.00	2.70	0.60	2.80	0.00	0.00	0.00	0.00	0.00	5.30	96		
Base/Leakage (kl/d)	4.80	3.30	8.00	33.30	0.00	0.00	2.70	0.60	2.90	0.00	0.00	0.00	0.00	0.00	5.30	61		
Infiltration (kl/d)																20		
Outside Contr. (kl/d)																		
Total (kl/d)																177	261	68%