


Table LBS6.2e: Land use and sewer flow composition - Existing Robertson System



	UH1 LDRes	UH2 MDRes	UH3 HdRes	UH4 VHDRes	UH5 Other	UH6 Unknown	UH7 Bus/Comm	UH8 Cluster	UH9 Flats	UH10 None	UH11 Farm/AH	UH12 Educ	UH13 Gov/Inst	UH14 Ind	UH15 Large	Sewer PDDWF	Water AADD	PDDWF/ AADD
Unit Erven (No. of)	2	0	8	345	0	0	1	0	3	0	0	0	0	0	29			
Domestic (kl/d)	1.00	0.00	2.50	79.60	0.00	0.00	0.50	0.00	1.10	0.00	0.00	0.00	0.00	0.00	7.60	92		
Base/Leakage (kl/d)	0.30	0.00	1.30	54.90	0.00	0.00	0.50	0.00	1.10	0.00	0.00	0.00	0.00	0.00	7.60	66		
Infiltration (kl/d)																43		
Outside Contr. (kl/d)																		
Total (kl/d)																201	247	81%
Unit Erven (No. of)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
Domestic (kl/d)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0		
Base/Leakage (kl/d)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0		
Infiltration (kl/d)																2		
Outside Contr. (kl/d)																		
Total (kl/d)																2	0	0%
Unit Erven (No. of)	0	0	0	69	0	0	0	0	1	0	0	0	0	0	0			
Domestic (kl/d)	0.00	0.00	0.00	12.40	0.00	0.00	0.00	0.00	0.20	0.00	0.00	0.00	0.00	0.00	0.00	13		
Base/Leakage (kl/d)	0.00	0.00	0.00	8.60	0.00	0.00	0.00	0.00	0.20	0.00	0.00	0.00	0.00	0.00	0.00	9		
Infiltration (kl/d)																8		
Outside Contr. (kl/d)																		
Total (kl/d)																29	33	89%
Unit Erven (No. of)	4	1	2	172	0	0	5	0	1	0	0	0	0	0	204			
Domestic (kl/d)	3.30	0.20	1.20	36.40	0.00	0.00	2.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	59.60	103		
Base/Leakage (kl/d)	1.10	0.10	0.70	25.10	0.00	0.00	2.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	59.60	89		
Infiltration (kl/d)																52		
Outside Contr. (kl/d)																		
Total (kl/d)																244	315	78%
Unit Erven (No. of)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	40			
Domestic (kl/d)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.80	12		
Base/Leakage (kl/d)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	11.80	12		
Infiltration (kl/d)																61		
Outside Contr. (kl/d)																		
Total (kl/d)																84	39	215%
Unit Erven (No. of)	172	596	644	2336	0	1	114	4	24	2	22	0	0	0	1425			
Domestic (kl/d)	119.30	324.80	241.50	534.30	0.00	0.20	77.40	4.30	15.00	1.70	17.00	0.00	0.00	0.00	405.40	1741		
Base/Leakage (kl/d)	41.00	140.90	130.30	368.30	0.00	0.20	77.40	4.30	15.10	1.70	17.10	0.00	0.00	0.00	405.40	1202		
Infiltration (kl/d)																695		
Outside Contr. (kl/d)																		
Total (kl/d)																3638	4948	74%
Unit Erven (No. of)	178	597	654	2922	0	1	120	4	29	2	22	0	0	0	1699			
Domestic (kl/d)	123.60	325.00	245.20	662.70	0.00	0.20	79.90	4.30	16.90	1.70	17.00	0.00	0.00	0.00	484.40	1961		
Base/Leakage (kl/d)	42.40	141.00	132.30	456.90	0.00	0.20	79.90	4.30	17.00	1.70	17.10	0.00	0.00	0.00	484.40	1377		
Infiltration (kl/d)																860		
Outside Contr. (kl/d)																		
Total (kl/d)																4198	5582	75%