


Table LBS6.4e: Land use and sewer flow composition - Future Robertson System



	UH1 LDRes	UH2 MDRes	UH3 HDRes	UH4 VHDRes	UH5 Other	UH6 Unknown	UH7 Bus/Comm	UH8 Cluster	UH9 Flats	UH10 None	UH11 Farm/AH	UH12 Educ	UH13 Gov/Inst	UH14 Ind	UH15 Large	Sewer PDDWF	Water AADD	PDDWF/ AADD
Unit Erven (No. of)	1	0	5	554	0	0	6	1	18	0	1	0	0	0	15			
Domestic (kl/d)	0.60	0.00	1.90	119.20	0.00	0.00	0.70	0.70	7.90	0.00	0.50	0.00	0.00	0.00	4.50	136		
Base/Leakage (kl/d)	0.20	0.00	1.00	82.20	0.00	0.00	0.70	0.70	8.00	0.00	0.50	0.00	0.00	0.00	4.50	98		
Infiltration (kl/d)																43		
Outside Contr. (kl/d)																		
Total (kl/d)																277	367	76%
Unit Erven (No. of)	0	0	0	100	0	0	0	0	0	0	0	0	0	0	0			
Domestic (kl/d)	0.00	0.00	0.00	23.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23		
Base/Leakage (kl/d)	0.00	0.00	0.00	15.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	16		
Infiltration (kl/d)																15		
Outside Contr. (kl/d)																		
Total (kl/d)																54	60	91%
Unit Erven (No. of)	1	0	0	63	0	0	0	0	40	155	0	0	0	0	0			
Domestic (kl/d)	0.50	0.00	0.00	11.00	0.00	0.00	0.00	0.00	18.40	17.00	0.00	0.00	0.00	0.00	0.00	47		
Base/Leakage (kl/d)	0.20	0.00	0.00	7.60	0.00	0.00	0.00	0.00	18.50	17.10	0.00	0.00	0.00	0.00	0.00	43		
Infiltration (kl/d)																18		
Outside Contr. (kl/d)																		
Total (kl/d)																108	159	68%
Unit Erven (No. of)	4	0	2	408	131	0	10	0	57	222	0	0	0	0	204			
Domestic (kl/d)	2.40	0.00	0.70	88.10	20.20	0.00	1.50	0.00	28.60	31.70	0.00	0.00	0.00	0.00	57.10	230		
Base/Leakage (kl/d)	0.80	0.00	0.40	60.70	13.90	0.00	1.50	0.00	28.80	31.80	0.00	0.00	0.00	0.00	57.10	195		
Infiltration (kl/d)																71		
Outside Contr. (kl/d)																		
Total (kl/d)																496	705	70%
Unit Erven (No. of)	6	0	228	155	75	0	0	0	7	0	24	0	0	0	40			
Domestic (kl/d)	6.80	0.00	144.60	65.80	29.80	0.00	0.00	0.00	9.50	0.00	29.60	0.00	0.00	0.00	15.00	301		
Base/Leakage (kl/d)	2.30	0.00	78.00	45.40	20.50	0.00	0.00	0.00	9.60	0.00	29.70	0.00	0.00	0.00	15.00	201		
Infiltration (kl/d)																76		
Outside Contr. (kl/d)																		
Total (kl/d)																577	831	70%
Unit Erven (No. of)	242	649	1369	4088	222	0	168	33	362	343	90	0	0	0	1489			
Domestic (kl/d)	164.70	330.70	512.90	932.40	60.10	0.00	104.80	31.90	197.70	78.10	58.00	0.00	0.00	0.00	410.70	2882		
Base/Leakage (kl/d)	56.60	143.50	276.80	642.80	41.40	0.00	104.70	31.90	199.00	78.50	58.20	0.00	0.00	0.00	410.70	2044		
Infiltration (kl/d)																934		
Outside Contr. (kl/d)																		
Total (kl/d)																5860	8283	71%
Unit Erven (No. of)	254	649	1604	5368	428	0	184	34	484	720	115	0	0	0	1748			
Domestic (kl/d)	175.00	330.70	660.10	1239.60	110.10	0.00	107.00	32.60	262.10	126.80	88.10	0.00	0.00	0.00	487.30	3619		
Base/Leakage (kl/d)	60.10	143.50	356.20	854.60	75.80	0.00	106.90	32.60	263.90	127.40	88.40	0.00	0.00	0.00	487.30	2597		
Infiltration (kl/d)																1158		
Outside Contr. (kl/d)																		
Total (kl/d)																7374	10405	71%