

Table LBW5.1: Design and evaluation criteria - Peak factors for water demand

Predominant land use	AADD (kℓ/d)	PWF	PDF	PHF
Low cost housing	<1000	1.50	1.90	3.60
	1000 - 5000	1.40	1.80	3.40
	5000 - 10000	1.35	1.70	3.30
	10000 - 15000	1.30	1.50	3.20
	15000 - 20000	1.25	1.40	3.10
	>20000	1.25	1.40	3.00
Residential	<1000	1.80	2.20	4.60
	1000 - 5000	1.65	2.00	4.00
	5000 - 10000	1.50	1.80	3.60
	10000 - 15000	1.40	1.60	3.50
	15000 - 20000	1.35	1.50	3.30
	>20000	1.30	1.50	3.00
Business/Commercial/Industrial	<5000	1.45	1.70	3.30
	5000 - 10000	1.30	1.60	3.15
	>10000	1.25	1.50	3.00