Treated Water	Requirement Measurement Blue Drop Standards	January 19 Ashton	January 19 Bonnievale	January 19 McGregor	January 19 Montagu	January 19 Robertson	Total Samples	Total Samples Complying
pH (at 25°C)	≥5.00 - ≤9.70	6.94	7.5	7.21	7.61	7.31	5	5
Conductivity (at 25°C)	≤170	36.5	67	11	56	9	5	5
Turbitity (NTU)	≤1.0 Operational ≤5.0 -Aeshetic	0.39	2	1	0.52	0.23	5	4
Colour (mg/L as Pt)	≤15	<4	<4	<4	<4	<4	5	5
Aluminium (µg/L as Al)	≤300	<12	<12	<12	<12	18	5	5
Iron (µg/L as Fe)	≤300 Aesthetic	<24	<24	<24	<24	<24	5	5
Free Chlorine (mg/L)	>0.0 - ≤5	1.2	0.41	2.4	0.64	1.1	5	5
E.Coli (cnt/100ml)	<1	<1	<1	<1	<1	<1	5	5
Total Coliform Bacteria	≤10	<1	<1	<1	<1	<1	5	5