

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
pH (at 25°C)	≥5.00 - ≤9.70	7.1	7.78	7.17	7.29	6.9	5.00	5.00
Conductivity (at 25°C)	≤170	33	99	14	53	12	5.00	5.00
Turbidity (NTU)	≤1.0 Operational	2.2	0.5	0.57	1	3.1	5.00	4.00
	≤5.0 -Aeshetic							
Colour (mg/L as Pt)	≤15	<4		<4	<4	<4	5.00	5.00
Aluminium (µg/L as Al)	≤300	<12	<12	<12	<12	<12	5.00	5.00
Iron (µg/L as Fe)	≤300 Aesthetic ≤2000 Chronic Health	<24	<24	<24	<24	<24	5.00	5.00
Free Chlorine (mg/L)	>0.0 - ≤5	0.81	0.37	2.1	1.2	0.49	5.00	5.00
E.Coli (cnt/100ml)	<1	<1	<1	<1	<1	<1	5.00	5.00
Total Coliform Bacteria	≤10	<1	<1	<1	<1	<1	5.00	5.00
							10.00	10.00
Percentage Compliant %							100.00	