

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
pH (at 25°C)	≥5.00 - ≤9.70	7.86	7.55	7.4	7.54	7.40	5.00	5.00
Conductivity (at 25°C)	≤170	50	105	13	53.3	11.5	5.00	5.00
Turbidity (NTU)	≤1.0 Operational	0.67	1.1	2.3	2.6	1.6	0.00	0.00
	≤5.0 -Aeshetic						5.00	5.00
Colour (mg/L as Pt)	≤15	<4	6	15	<4	<4	5.00	5.00
Aluminium (µg/L as Al)	≤300	23	127	736	161	136	5.00	4.00
Iron (µg/L as Fe)	≤300 Aesthetic ≤2000 Chronic Health	41	27	54	<24	<24	5.00	5.00
Free Chlorine (mg/L)	>0.0 - ≤5	0.58	<0.05	<0.05	0.55	0.59	5.00	5.00
E.Coli (cnt/100ml)	Not Detected	<1	<1	<1	<1	<1	5.00	5.00
Total Coliform Bacteria	≤10	<1	<1	2	4	<1	5.00	5.00
							10.00	10.00
Percentage Compliant %							100.00	