

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
pH (at 25°C)	≥5.00 - ≤9.70	8.06	8.20	8.09	8.05	7.87	5.00	5.00
Conductivity (at 25°C)	≤170	55	148	13	60.5	8	5.00	5.00
Turbidity (NTU)	≤1.0 Operational	1.2	0.50	0.35	0.44	3.4	0.00	0.00
	≤5.0 -Aeshetic						5.00	5.00
Colour (mg/L as Pt)	≤15	<4	<4	<4	<4	<4	5.00	5.00
Aluminium (µg/L as Al)	≤300	87	56	140	154	499	5.00	4.00
Iron (µg/L as Fe)	≤300 Aesthetic ≤2000 Chronic Health	128	<24	<24	33	141	5.00	5.00
Free Chlorine (mg/L)	>0.0 - ≤5	0.81	0.12	2.1	0.18	0.30	5.00	5.00
E.Coli (cnt/100ml)	Not Detected	<1	<1	<1	<1	<1	5.00	5.00
Total Coliform Bacteria	≤10	<1	<1	2	<1	<1	5.00	5.00
							10.00	10.00
Percentage Compliant %							100.00	