

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
		pH (at 25°C)	≥5.00 - ≤9.70	6.87	7.99	7.60	7.47	7.30
Conductivity (at 25°C)	≤170	67	132	13.0	64	24	5.00	5.00
Turbidity (NTU)	≤1.0 Operational						0.00	0.00
	≤5.0 -Aeshetic	2.3	0.48	0.55	0.44	0.33	5.00	5.00
Colour (mg/L as Pt)	≤15	<4	<4	<4	<4	<4	5.00	5.00
Aluminium (µg/L as Al)	≤300	629	43	192	278	<12	5.00	4.00
Iron (µg/L as Fe)	≤300 Aesthetic							
	≤2000 Chronic Health	143		<24	<24	<24	5.00	5.00
Free Chlorine (mg/L)	>0.0 - ≤5	0.36	0.06	1.1	0.37	0.77	5.00	5.00
E.Coli (cnt/100ml)	Not Detected	<1	<1	<1	<1	<1	5.00	5.00
Total Coliform Bacteria	≤10	<1	<1	<1	<1	<1	5.00	5.00
							10.00	10.00
Percentage Compliant %							100.00	