

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
	pH (at 25°C)	≥5.00 - ≤9.70	6.92	7.06	7.02	7.01	6.99	5.00
Conductivity (at 25°C)	≤170	28	33	11.5	52	8.5	5.00	5.00
Turbidity (NTU)	≤1.0 Operational						0.00	0.00
	≤5.0 -Aeshetic	1	1.0	0.78	0.52	0.37	5.00	5.00
Colour (mg/L as Pt)	≤15	<4	<4	<4	<4	<4	5.00	5.00
Aluminium (µg/L as Al)	≤300	186	273	259	267	54	5.00	5.00
Iron (µg/L as Fe)	≤300 Aesthetic ≤2000 Chronic Health	55	31	<24	28	<24	5.00	5.00
Free Chlorine (mg/L)	>0.0 - ≤5	1.3	0.10	0.88	0.78	0.76	5.00	5.00
E.Coli (cnt/100ml)	Not Detected	<1	<1	<1	<1	<1	5.00	5.00
Total Coliform Bacteria	≤10	<1	<1	<1	<1	<1	5.00	5.00
							10.00	10.00
Percentage Compliant %							100.00	