

Treated Water	Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu
	pH (at 25°C)	≥5.00 - ≤9.70	7,2	7,9	7,36
Conductivity (at 25°C)	≤170	82,7	223	17	76
Turbidity (NTU)	≤1.0 Operational	<0,32	0,6	0,64	0,45
	≤5.0 -Aeshetic				
Colour (mg/L as Pt)	≤15	<10	<10	<10	<10
Aluminium (µg/L as Al)	≤300	<50	<50	<50	<50
Iron (µg/L as Fe)	≤300 Aesthetic	<10	<10	<50	<50
	≤2000 Chronic Health				
Free Chlorine (mg/L)	>0.0 - ≤5	0,63	0,37	1,3	0,14
E.Coli (cnt/100ml)	Not Detected	0	0	0	0
Total Coliform Bacteria	≤10	<10	<10	<10	<10
Percentage Compliant %					

Robertson	Total Samples	Total Samples Complying
6,66	5,00	5,00
23,1	5,00	4,00
0,7	0,00	0,00
	5,00	5,00
<10	5,00	5,00
<50	5,00	5,00
<50	5,00	5,00
0,36	5,00	5,00
0	5,00	5,00
<10	5,00	5,00
	10,00	10,00
	100,00	