

21-Feb-23		Requirement Measurement Blue Drop Standards	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples	Total Samples Complying
<b>Treated Water</b>									
Inflow ML									
pH (at 25°C)		≥5.00 - ≤9.70	7.06	7,36	6,79	7,32	6,46	5,00	5,00
Conductivity (at 25°C)		≤170	73	49,2	9,6	48,4	6.8	5,00	5,00
Turbidity (NTU)		≤1.0 Operational							
		≤5.0 -Aeshetic	2.2	1,5	1,3	0,32	4	5,00	5,00
Colour (mg/L as Pt)		≤15	<4	7	7	5	11	5,00	5,00
Aluminium (µg/L as Al)		≤300	226	535	476	<40	938	5,00	2,00
Iron (µg/L as Fe)		≤300 Aesthetic ≤2000 Chronic Health	40	48	58	<20	257	5,00	5,00
Free Chlorine (mg/L)		>0.0 - ≤5	1.2	0,05	1,3	0,05	0,22	5,00	5,00
E.Coli (cnt/100ml)		Not Detected	<1	<1	210	42	<1	5,00	5,00
Total Coliform Bacteria		≤10	<1	2	<1	<1	<1	5,00	5,00
								10,00	10,00

