

| 29-Jul-23 | | Requirement | Ashton | Bonnievale | McGregor | Montagu | Robertson | Total Samples | Total Samples Complying |
|-------------------------|--|--|--------|------------|----------|---------|-----------|---------------|-------------------------|
| Treated Water | | Measurement Blue Drop Standards | | | | | | | |
| Inflow ML | | | | | | | | | |
| pH (at 25°C) | | ≥5.00 - ≤9.70 | 6,92 | 7,15 | 6,77 | 6,57 | 7,11 | 5,00 | 5,00 |
| Conductivity (at 25°C) | | ≤170 | 37,5 | 41,3 | 10,1 | 33,7 | 6,6 | 5,00 | 5,00 |
| Turbidity (NTU) | | ≤1.0 Operational | | | | | | | |
| | | ≤5.0 -Aeshetic | 1,5 | 3,3 | 0,72 | 0,89 | 9,4 | 5,00 | 4,00 |
| Colour (mg/L as Pt) | | ≤15 | <4 | <4 | <4 | <4 | <4 | 5,00 | 5,00 |
| Aluminium (µg/L as Al) | | ≤300 | 104 | 848 | 171 | 341 | 473 | 5,00 | 2,00 |
| Iron (µg/L as Fe) | | ≤300 Aesthetic ≤2000 Chronic Health | 35 | 94 | <20 | 30 | 148 | 5,00 | 5,00 |
| Free Chlorine (mg/L) | | >0.0 - ≤5 | 1,5 | 1,2 | 1,6 | 2,5 | 0,15 | 5,00 | 5,00 |
| E.Coli (cnt/100ml) | | Not Detected | <1 | <1 | <1 | <1 | <1 | 5,00 | 5,00 |
| Total Coliform Bacteria | | ≤10 | <1 | <1 | <1 | <1 | <1 | 5,00 | 5,00 |
| | | | | | | | | 10,00 | 10,00 |

| Parameters | Unit | GENERAL LIMITS | SPECIAL LIMITS | 27-Jul-23 | | | | Requirement Measurement (Irrigation 500m³) | Mc-Gregor | Total Samples | Total Samples Complying |
|--------------------------|------------|---------------------------|-------------------|-----------|------------|---------|-----------|--|-----------|---------------|-------------------------|
| | | | | Ashton | Bonnievale | Montagu | Robertson | | | | |
| Average daily flows (ML) | | | | | | | | | | | |
| pH | at 25°C | 5.5 - 9.5 | 5.5 - 7.5 | 7,30 | 7,72 | 7,43 | 7,4 | 6.00 - 9.00 | 7,7 | 5 | 5 |
| Conductivity | mS/m | <70.0 - <150 | mS/m above intake | 266 | 117 | 137 | 217 | <200 | 144 | 5 | 3 |
| COD Unfiltered | mg/L | | | 103 | 66,7 | 78,5 | 167 | | | 0 | 0 |
| COD Filtered | mg/L | <75.0 After Algae Removal | 30 | 65,0 | 54,4 | 52,0 | 102,0 | <400 | 114 | 5 | 4 |
| Ammonia as N | mg/L | 6.0 max | 2.0 | 52,3 | <0,10 | 15,2 | 48,6 | N/A | | 4 | 1 |
| Nitrate as N | mg/L | 15.0 max | 1.5 | <0,20 | 0,52 | 0,39 | <0,20 | N/A | | 4 | 4 |
| Nitrite as N | mg/L | 15.0 max | | <0,20 | <0,20 | <0,20 | <0,20 | N/A | | 0 | 0 |
| Free Chlorine | mg/L | <0.25 | 0 | 0,33 | 3,4 | 0,41 | <0,05 | N/A | | 0 | 0 |
| TSS | mg/L | 25 | 10 | 31 | 11 | 22 | 88 | N/A | | 4 | 2 |
| Ortho-P | mg/L | 10 | 1 med 2,5max | 5,30 | 1,7 | 6,7 | 4,7 | | | | 0 |
| Soap, oil or grease | mg/L | 3 | 0 | | | | | | | | 0 |
| Faecal Coliforms | Org/100 ml | 1000 max | 1000 | >2419 | 6 | >2419 | 2419 | <100 000 | 9 100 | 5 | 2 |
| E Coli | Org/100 ml | 1000,0 | | >2419 | 4 | >2419 | 2419 | N/A | | 5 | 1 |
| | | | | | | | | | 100% | 37,00 | 22,00 |

| | | | | | | | | | | | |
|----------------|--|--|--|--|--|--|--|--|--|--|--|
| Ashton WWTW | The plant does not comply with NH3 because there is no backup Generator so the loadshedding has an impact on the nitrification process. | | | | | | | | | | |
| | The Chlorine dosing is not in operation, waiting for the pipes. | | | | | | | | | | |
| Montagu WWTW | The plant failed on NH# because the backup Generator doesn't start on Auto during loadshedding at night, the stand by guys do come out at night to operate the Generator. The microbiological parameters also failed poor monitoring and the dosing is not adequate. | | | | | | | | | | |
| Robertson WWTW | The plant does not have a backup Generator so its not performing well and its is still overloaded but the Press Machine is in operation. The microbiological parameters are failing as well due to inadequate dosing of Ca(ClO)2. | | | | | | | | | | |
| | | | | | | | | | | | |

59,46