

Drinking water Quality report

Nov-25		Drinking Water Quality Report							
Treated Water	Requirement Measurement Standards Limits	Ashton	Bonnievale	McGregor	Montagu	Robertson	Total Samples l/s	Total Samples Complying	
	pH (at 25°C)	≥5.00 - ≤9.70	7,29	7,96	6,49	7,53	6,82	5,00	5,00
	Conductivity (at 25°C)	≤170	61,8	152	9,31	72,8	19,2	5,00	5,00
	Turbidity (NTU)	≤1.0 Operational						0,00	0,00
		≤5.0 -Aeshetic	0,31	0,48	0,44	<0,30	0,62	5,00	5,00
	Colour (mg/L as Pt)	≤15	<10.0	<10	<10	<10	<10	5,00	5,00
	Aluminium (µg/L as Al)	≤300	64,5	98,9	19,8	113	24,1	5,00	5,00
	Iron (µg/L as Fe)	≤300 Aesthetic ≤2000 Chronic Health	<20	<0,20	<20	<20	<20	5,00	5,00
	Free Chlorine (mg/L)	>0.0 - ≤5	0,29	0,2	0,24	0,3	0,82	5,00	5,00
E.Coli (cnt/100ml)	Not Detected	0	0	0	0	0	5,00	5,00	
Total Coliform Bacteria	≤10	0	0	0	1	0	5,00	5,00	
							45,00	45,00	